

Crestline Village Water District
System Report on: 12/31/24

Water Storage (Gal)	Capacity	Gallons/ Foot	Level (FT)	Current Storage	% of Capacity
Beacon I & II	385,354	16,752	18.17	304,384	78.99%
Saxon	337,674	14,679	18.75	275,231	81.51%
Pinecrest I & II	2,063,492	54,302	28.57	1,551,408	75.18%
Zurich	380,500	18,789	17.29	324,862	85.38%
Lakeview	1,230,212	27,955	34.23	956,900	77.78%
Old Mill	705,900	27,151	24.03	652,439	92.43%
Barn	444,443	19,752	19.45	384,176	86.44%
Wilson	983,681	33,915	24.83	842,109	85.61%
Chillon	337,674	14,679	17.32	254,240	75.29%
Brookside	748,067	28,772	19.39	557,889	74.58%
Chamois	1,026,532	39,482	21.84	862,287	84.00%
Total	8,643,529		243.87	6,965,925	80.59%

For Month of: December 2024

WELLS	Production M-T-D (Cubic Feet)	Status
Altdorf	95,884	On
Pioneer-2	64,577	On
Pioneer-1	108,991	On
Old Mill Springs	44,228	On
Maple Springs	116,174	On
Willow Springs	47	Off
Brookside Springs	66,629	On
Hillside Springs	0	Off
Pinecrest 1 & 2	96,023	On
Pinecrest Vertical	162,584	On
Cypress Vertical	0	Off
Anderson Vertical	111,822	On
Wilson Springs 1 & 2	223,314	On
Wilson Vertical	35,518	On
Felsen Vertical	170,920	On
Horst	137,485	On
Jewel 64	100,597	On
Cathcart	34,807	On
Bergschrund	58,653	On
Electra Vertical	0	Off
Chamois Vertical	36,384	On
	0	0
	0	0
	0	0
Lewter	0	Off
Total	1,664,637	

C.L.A.W.A.	FLOWS - GPM				Production M-T-D (Cubic Feet)
	Timed	Requested	Variance	% Variance	
CF - Crestline	0	0	0	0.00%	0
Mile High 2"	0	0	0	0.00%	0
Mile High 4"	0	0	0	0.00%	0
Pinecrest 2"	0	0	0	0.00%	0
Pinecrest 4"	51	50	1	2.00%	479,144
Lake Drive 2"	0	0	0	0.00%	0
Lake Drive 4"	0	0	0	0.00%	0
Camp Seely	0	0	0	0.00%	47,753
Total	51	50	1	2.00%	526,897

<u>December Purchases</u>	GPM	Cubic Feet	<u>Wells</u>	GPM	Cubic Feet
Last Year M-T-D:	45.9	273,927		308.0	1,838,118
Actual M-T-D:	88.3	526,897		278.9	1,664,637
Over/(Under) Last Year:	42.4	252,970.0		(29.1)	(173,481.0)

<u>Total</u>	GPM	Cubic Feet
Last Year M-T-D:	353.9	2,112,045
Actual M-T-D:	367.2	2,191,534
Over/(Under) Last Year:	13.3	79,489.0