



State Water Resources Control Board Division of Drinking Water

February 26, 2024

Thomas G. Weddle
General Manager
Crestline Village CWD – Division 10
777 Cottonwood Drive
Crestline, CA 92325
tweddle@cvwater.com

Dear Mr. Weddle:

INACTIVATION OF CYPRESS VERTICAL WELL – CRESTLINE VILLAGE CWD – DIVISION 10 – (SYSTEM NO. 3610015)

This letter documents the inactivation of Cypress Vertical Well (PS Code: 3610015_056_056). The State Water Resources Control Board, Division of Drinking Water (Division) received an e-mail dated February 21, 2024 (Enclosure 1) from Crestline Village CWD – Division 10 public water system (District) requesting that Cypress Vertical Well to be inactivated. The email also attaches photos demonstrating that Cypress Vertical Well has been physically separated from the system (Enclosure 2).

The Division hereby changes the status of the well from “Active” to “Inactive.” The well is no longer required to be monitored for water quality and cannot be used as a potable source without first obtaining a permit amendment from the Division. However, if the District continues to monitor the well under inactive status, the Division encourages the District’s laboratory to continue to submit the results electronically to California Laboratory Intake Portal (CLIP). If the well will no longer be used, the District should properly destroy the well per Department of Water Resources (DWR) Bulletins 74-80 and 74-90. Please forward a copy to the San Bernardino County well destruction permit and DWR destruction log if/when completed.

E. JOAQUIN ESQUIVEL, CHAIR | ERIC OPPENHEIMER, EXECUTIVE DIRECTOR

464 W. 4th Street, #437, San Bernardino, CA 92401 | www.waterboards.ca.gov

If you have any questions regarding this letter, please contact Luis Ortiz at (909) 383-4314 or by e-mail at Luis.Ortiz@waterboards.ca.gov.

Sincerely,

Wei H. Chang, P.E.
District Engineer
San Bernardino District
Southern California Filed Operations Branch

cc:

1. David Sale, Field Lead, Crestline Village Water District, dcsale@cvwater.com

Enclosures:

1. E-mail from Crestline Village CWD for Cypress Vertical Well inactivation
2. Photos of physical separation

Enclosure 1

From: Mike Casas <mjcasas@cvwater.com>

Sent: Wednesday, February 21, 2024 4:17 PM

To: Ortiz, Luis@Waterboards <Luis.Ortiz@Waterboards.ca.gov>

Subject: RE: Crestline Village CWD - CA3610015 - Cypress 056 & Felsen 071 Vertical Wells - Nitrate/Nitrite Results

EXTERNAL:

Attached are some pictures of Cypress well showing it disconnected inside the pumphouse. We cannot use Cypress anymore because the well casing collapsed and state regs will not allow us to drill on that property due to its proximity to a waterway. Thanks Luis

Enclosure 2

Cypress Vertical Well (PS Code: 3610015_056_056)

